

Jaida Ohokannoak

From: Keith Morrison <kmorrison@nirb.ca>
Sent: June-16-17 2:16 PM
To: mlusty@gov.nu.ca
Subject: RE: NIRB 13UN037 Rankin Inlet Water Licence Amendment

Megan, upon further review of the info provided, it would appear that some kind of pad and short access road off the existing road would be required to place the pump for Lower Landing Lake. Information on this (where it would be, how it is to be built, *et cetera*), and further information on the extended pipeline (buried/aboveground) would also need to be submitted in addition to what was requested in my previous email.

From: Keith Morrison [<mailto:kmorrison@nirb.ca>]
Sent: June-15-17 9:51 AM
To: mlusty@gov.nu.ca
Subject: NIRB 13UN037 Rankin Inlet Water Licence Amendment

Hello, Megan. I've been reviewing the submission made to NIRB regarding the proposed extension of the Rankin Inlet water line from Char River to Lower Landing Lake, and I can't find anything in the submitted documents regarding how the pipeline will be crossing Char River to the proposed new pump location. Without that information, it's impossible to do a proper scoping and screening of the project.

While we don't necessarily require detailed engineering diagrams (as the Water Board will), we need to have at minimum some idea of what would be done.

--

Keith Morrison
Technical Advisor II
Nunavut Impact Review Board
Ph 867-983-4617