

[illegible]

Personnel on site: 1
Days on site: 1000
Total Person days: 1000
Period of operation: from 2017-06-09 to 2024-05-01
Proposed term of operation: from 2024-05-01 to 2024-05-01

Activités

Activités

Emplacement	Type d'activité	Statut des terres	Historique du site	Site à valeur archéologique ou paléontologique	Proximité des collectivités les plus proches et de toute zone protégée
GRA-1 Nipissar Lake Water Supply	Sampling sites	Municipal	Location of Nipissar Lake Pumphouse and intake for the community water supply. Water is transported via underground pipeline to the Williamson Lake Pumphouse in Rankin Inlet for treatment and distribution.	No known archaeological/paleontological value.	With Hamlet of Rankin Inlet Municipal Boundaries.
GRA-6 Char River Water Pumped to Nipissar Lake	Sampling sites	Municipal	Current intake location for seasonal resupply pipeline.	No known archaeological/paleontological value.	With Hamlet of Rankin Inlet Municipal Boundaries.
GRA-7 Lower Landing Lake (approximate proposed pumping location)	Sampling sites	Municipal	Proposed intake location and extension of seasonal intake. Lower Landing Lake feeds Char River.	No known archaeological/paleontological value.	With Hamlet of Rankin Inlet Municipal Boundaries.
GRA-3 Sewage Treatment Facility	Waste disposal	Municipal	Sewage Treatment Facility - samples are collected from within the building before effluent discharge to Prairie Bay, Hudson Bay.	No known archaeological/paleontological value.	Within Hamlet of Rankin Inlet Municipal Boundaries.

Engagement de la collectivité et avantages pour la région

Collectivité	Nom	Organisme	Date de la prise de contact
Rankin Inlet	Megan Lusty	Hamlet Council - update on current water volumes in Nipissar Lake and intention to move intake to Lower Landing Lake, pending regulatory approvals.	2017-01-30

Autorisations

Indiquez les zones dans lesquelles le projet est situé

Kivalliq

Autorisations

Organisme de régulation	Description des autorisations	État actuel	Date de l'émission/de la demande	Date d'échéance
Office des eaux du Nunavut	Type 'A' Water Licence 3AM-GRA1624	Active	2016-05-02	2024-05-01
Autre	Nunavut Planning Commission - NPC File #148311, 3AM-GRA1624 GN-CGS Rankin Inlet Water Licence Amendment. Project proposal conforms to the KRLUP. NPC determined significant modification to the project and screening is required by the NIRB.	Active	2016-06-19	
Autre	NIRB Screening Decision Report, File #13UN037. Screening decision for the GN-CGS "Hamlet of Rankin Inlet: Amendment Application - Seasonal Replenishment of Nipissar Lake".	Active	2014-06-26	
Autre	NIRB Exempt from screening, File #13UN037. Application Exempt from the Requirement for Screening pursuant to Section 12.4.3 of the NLCA: GN-CGS "Hamlet of Rankin Inlet: Amendment Application - Seasonal Replenishment of Nipissar Lake".	Active	2015-05-27	

Utilisation de matériel

Équipement à utiliser (y compris les perceuses, les pompes, les aéronefs, les véhicules, etc.)

Type d'équipement	Quantité	Taille – Dimensions	Utilisation proposée
Diesel powered generator	1	75hp, same as currently used	Power pump for water transfer from Char River/Lower Landing Lake to Nipissar Lake
Pump	1	Maximum 0.04 m3/s, same as currently used	Pump for water transfer from Char River/Lower Landing Lake to Nipissar Lake
Floating Intake	1	Conforms with DFO Guidelines, same as currently used	Water intake from Char River/Lower Landing Lake
Seacan	1	20ft, same as currently used	Houses pump and generator at Char River/Lower Landing Lake
Pipeline	1	4.05km (same as currently used) + 0.2km (new, to be installed upon approval)	Overland resupply pipeline from Char River/Lower Landing Lake

Décrivez l'utilisation du carburant et des marchandises dangereuses

Decrivez l'utilisation de carburant :	Type de carburant	Nombre de conteneurs	Capacité du conteneur	Quantité totale	Unités	Utilisation proposée
Diesel	fuel	1	250	250	Gallons	Generator

Consommation d'eau

Quantité quotidienne (m3)	Méthodes de récupération de l'eau proposées	Emplacement de récupération de l'eau proposé
3485	Seasonal floating intake	Lower Landing Lake

Déchets

Gestion des déchets

Activités du projet	Type des déchets	Quantité prévue	Méthode d'élimination	Procédures de traitement supplémentaires
Waste disposal	Eaux usées (matières de vidange)	772,000 m3 (projected 2024 volume)	Discharge to Prairie Bay, Hudson Bay.	Wastewater Treatment Plant with Monster Augers

Répercussions environnementales :

Rankin Inlet water consumption has exceeded natural recharge to Nipissar Lake for many years. The overland resupply pipeline from Char River was constructed to supplement the water in Nipissar Lake, to prevent further decrease in water level. The “Nipissar Lake and Lower Landing Lake Water Balance Assessment” by Golder Associates (attached) details the suitability of Lower Landing Lake to provide supplementary water to Nipissar Lake for a significantly longer term than the current Water Licence 3AM-GRA1624 expiry on May 1, 2024. Using Nunavut Bureau of Statistics population projects, the required supplementary water volumes are not expected to exceed 10% of the flow in Char River until 2082, using current per capita consumption rates. Water samples collected in 2014, 2015 and 2016 have determined that Lower Landing Lake, Char River and Nipissar Lake all have similar water chemistry. The Water Pumping Adaptive Management Plan details this monitoring and is also attached.

Description de l'environnement existant : Environnement physique

Description de l'environnement existant : Environnement biologique

Description de l'environnement existant : Environnement socio-économique

Identification des répercussions et mesures d'atténuation proposées

Répercussions cumulatives

Impacts

Identification des répercussions environnementales

[illegible]

-			-	-	-		-	-	-	-	-	-	-	-		-	-	-	-	-			-	-	-	-	-		
---	--	--	---	---	---	--	---	---	---	---	---	---	---	---	--	---	---	---	---	---	--	--	---	---	---	---	---	--	--

(P = Positive, N = Négative et non gérable, M = Négative et gérable, U = Inconnue)

Project Map

