



**Keith Morrison**

Manager, Impact Assessment  
Nunavut Impact Review Board (NIRB)  
P.O. Box 1360, Cambridge Bay, NU X0B 0C0  
By email: [kmorrison@nirb.ca](mailto:kmorrison@nirb.ca); [info@nirb.ca](mailto:info@nirb.ca)

**Jody Kusugak**

Commercial Development Officer Trainee  
Nunavut Airport Division, Government of Nunavut  
Economic Development and Transportation (EDT)  
Building 1104, Inuksugait Plaza,  
P.O. Box 1000, Station 1500  
Iqaluit, NU X0A 0H0  
By email: [jkusugak@gov.nu.ca](mailto:jkusugak@gov.nu.ca); [hangidlik@gov.nu.ca](mailto:hangidlik@gov.nu.ca)

**Megan Larose**

Qulliq Energy Corporation  
243 Umiaq Crescent  
Iqaluit Nunavut X0A 0H0  
By email: [MLarose@qec.nu.ca](mailto:MLarose@qec.nu.ca)

**Richard Dwyer**

Manager of Licensing  
Nunavut Water Board (NWB)  
P.O. Box 119, Gjoa Haven, NU X0B 1J0  
By email: [richard.dwyer@nwb-oen.ca](mailto:richard.dwyer@nwb-oen.ca)  
[licensing@nwb-oen.ca](mailto:licensing@nwb-oen.ca)

**Robert Chapple**

Director, Planning & Lands  
Government of Nunavut  
Community and Government Services (CGS)  
P.O. Box 272, Kugluktuk, NU X0B 0E0  
By email: [rchapple@gov.nu.ca](mailto:rchapple@gov.nu.ca);  
[kwasilyshen11@gov.nu.ca](mailto:kwasilyshen11@gov.nu.ca)

Dear Mr. Morrison, Mr. Dwyer, Ms. Kusugak, Mr. Chapple, Ms. Larose:

**RE: NPC File # 149565[Cambridge Bay New Power Plant and Bulk Fuel Storage Facility]**

The following works and activities have been proposed in the above-noted project proposal:

1. Construction of a new power plant in Cambridge Bay consisting of a new 90,000 L horizontal fuel tank, two vertical fuel tanks with 2 million litres capacity, secondary containment berm, and an approximately 400 metres long above ground fuel pipeline to connect to the PPD facility, and appropriate fuel pumping facilities.
2. The site will also include space for a Quonset garage, concrete pad for transformers, storage for two sea cans, pole racks, and oil and glycol drum storage and containment. The proposed location for the new power plant is on the east side of Tank Farm Road (Road R36), approximately 2 kilometres (km) southwest of the Hamlet of Cambridge Bay, approximately 1 km east of the Cambridge Bay Airport, and approximately 400 metres northeast of the PPD bulk fuel storage facility.
3. Location: Kitikmeot Region; [Cambridge Bay].

A complete description of the project proposal reviewed by the NPC can be accessed online using the link below. The Nunavut Planning Commission (NPC) has determined that this project proposal is outside the area of an applicable

regional land use plan. The project proposal requires screening by the Nunavut Impact Review Board (NIRB) because it does not belong to a class of exempt works or activities set out in Schedule 12-1 of the Nunavut Agreement.

By way of this letter, the NPC is forwarding the project proposal to the NIRB for screening. Project materials are available at the following address:

<https://lupit.nunavut.ca/portal/project-dashboard.php?appid=149565&sessionid=>

This decision applies only to the above noted project proposal as submitted. Proponents may not carry out projects and regulatory authorities may not issue licenses, permits and other authorizations in respect of projects if a review by the NPC is required.

If you have any questions, please do not hesitate to contact me at (867) 983-4640.

Sincerely,

A handwritten signature in blue ink, consisting of the letters 'S' and 'A' connected by a horizontal line.

Solomon Amuno, PhD  
Senior Planner  
Nunavut Planning Commission